




International Journal of Multidisciplinary Research in Science, Engineering and Technology

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)



Impact Factor: 8.206

Volume 8, Issue 12, December 2025



Compression & Reconstruction of Smart Grid Data using Discrete Wavelet Transform

Mr. Datta Yashawant Giri¹, Mr. Pawale Sunil Suresh²

Department of Electrical Engineering, Sau Sundarbai Manik Adsul Polytechnic, Chas, Ahilyanagar,
Maharashtra, India^{1,2}

ABSTRACT: smart grid offers safe, reliable, and useful electricity. Phasor measuring units, smart meters & other monitoring and measurement devices in the smart grid keep track of statuses at every grid level. As a result, utilities, control centers & customers must exchange and retain an enormous amount of data in real time. As a result, data storage and communication require efficient data compression. To accurately reflect status of the system & regenerate nearly flawlessly on receiving side, compression should preserve all of the data's critical information. This work uses the discrete wavelet transform to recover compressed voltage sag signals. With reduced data, the disruptions can be communicated more quickly. Because the proposed system uses lesser filters and few decomposition layers, it is simpler than the previous design. The results of the simulation demonstrate improvement in the reconstruction error & compression ratio by minimizing their values. This design is time-saving and simple to use.

KEYWORDS: compression, decomposition, reconstruction, noise, smart grid, wavelet transform

I. INTRODUCTION

The current electrical grid has been uncertain, susceptible to blackouts and brownouts, giving significant transmission losses, low power quality, providing insufficient electricity, and discouraging the combination of distributed energy sources. Restructuring the power delivery system from the ground up was necessary to mitigate these problems. A developing combination of many technologies, the smart grid, or modernization of the electric grid, aimed to significantly alter the electrical power grid [1]. To enable widespread observability and real-time monitoring, a significant quantity of smart devices like meters and monitors were installed across the distribution network. In terms of computing knowledge, an interaction interface, and the ability to deal with signals and share knowledge, it generated new requirements. Consequently, there was a significant rise in data storage and interchange. Achieving an effective usage of channel bandwidth and a decreased requirement for storing electrical data were crucial in that situation [2].

The smart grid's unique characteristics included improved power security, detailed analysis to support system control, monitoring capability with data integration and efficient communication to satisfy power demand. Some of the smart grid's amazing features were low costs and efficient energy use. The installation of the smart grid necessitated sophisticated communication between the devices that generated and consumed power. Choosing and using the most advanced digital signal processing algorithms had a significant impact on these devices' efficiency [3]. Data produced by the Phasor Measurement Unit (PMU) had been compressed using the wavelet transform. Two separate wavelets, Coiflet1(coif1) and Daubechies2, were used for compression. The results showed that db2 compressed PMU-generated signals much more effectively than coif1 [4]. It suggested using compressed sensing to identify frequencies of harmonics that disrupted the fundamental current and voltage signals in power networks. By choosing a small number of samples at random, generated a measurement matrix and then moved the signal in compressed form from time to frequency form using linear transform. The signal was then reconstructed using the inverse linear transform on a few recorded samples [5].

It used a compression method for electrical disturbing signal with Wavelet Packet Transform (WPT) and Discrete Wavelet Transform (DWT). Minimal Description Length (MDL) was a criterion for selecting an appropriate wavelet function and ideal quantity of wavelets preserved elements for signal reconstruction [6]. A lossy mechanism to compress data in smart distribution system was presented by Singular Value Decomposition (SVD). The proposed technique notably reduced the data quantity while accurately recreating the original signal [7].



International Journal of Multidisciplinary Research in Science, Engineering and Technology (IJMRSET)

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)

It was important to use multiple compression techniques for data with diverse characteristics. The research suggested a fusion lossy and lossless data compression technique based on signal properties to overcome such problems [8]. The wavelet packet transform on which it was based optimized the data compressing in accordance with the intended data loss. A specialized reconstructing technique that effectively created images straight from the compressed data was further developed [9]. The challenge of processing and storing excessive amounts of aging data in IGBT failure diagnosis was addressed by an adaptive threshold wavelet compression technique [10]. Wavelet decomposition was used, followed by range coding and quantization appropriate for floating-point data [11]. An innovative multivariate data compression approach was put forth for Internet of Things smart metering. To minimize data dimension, the method took advantage of the cross-correlation between several variables that smart meters sensed [12]. The matrix having ideal quantity of singular values was subjected to the Optimal Singular Value Decomposition (OSVD); the remaining values were ignored. The ratio of compression and retrieved data quality allowed goal achievement [13]. Sub bands or wavelet transform decomposition levels were used to segment the modified spectrum in the models that were suggested to estimate the adaptive spectral envelope [14].

It used basis, matching, and orthogonal matching pursuit as sensing methods to recover signals lost as a result of transmission line power failures. The actual data represented the real time current and voltage levels. Although it required more samples than orthogonal matching pursuit, matching pursuit was the best choice for actual electrical fault recovery as it required just a little of machine time. Basis and orthogonal matching employed fewer random samples, but they required more processing time for signal restoration [15].

Wavelet Packet Decomposition (WPD) were utilized to analyze, denoise and compress smart grid system data. WPD provided sufficient redundancy removal and feature property retention to enhance noise mitigation, boost compression, and control data accuracy degradation [16]. It used weight-based entropy to identify the optimum basis tree from complete WPT for denoising and signal compression. A modified minimum description length technique could be used to modify the denoising threshold without requiring a noise measurement computation [17]. A comprehensive assessment had been done for the importance of wavelet transform for different simulated or actual data by comparative studies on digital signal processing techniques [18]. It worked on a wavelet-based method that applied DWT to reduce noise and compress smart grid data [19]. This technique tested the effectiveness on Phasor Measurement Unit data by using wavelet packet transform to break down the signal for one to five scale [20]. A wavelet packet transform design for level three, data compression and reconstruction was represented utilizing lower-order wavelets. It operated on the phasor measurement unit current magnitude signals and voltage sag signals [21]. In order to obtain excellent compression of power quality disturbances, it investigated the best wavelet and the ideal number decomposition scale [22].

A fuzzy-based data compression method was put forth with the goal of lessening the computing load associated with data analysis in smart grids [23]. A traditional method of evaluating manufacturing quality involved reconstructing the shape of manufactured workpieces to create a digital version of the physical product and assessing the quality further [24]. Surface reconstruction techniques were applied to a cloud of data points taken from the workpiece using reverse engineering techniques. The approach used the bat algorithm, a wellknown metaheuristic technique. For huge ultrasonic data compression, it created neural network models based on unsupervised learning as well as a novel multilayer autoencoder with excellent compression capabilities [25]. It explained the Huffman method [26], contrasted it with run length encoding and arithmetic coding, and discussed how these three algorithms were used in JPEG compression. Compression technology was revolutionized by the emergence of large artificial intelligence models that were trained on enormous volumes of data [27]. The computational difficulties utilized the advantages of lossless compression in a lossy mode and vice versa for data restoring, associated intelligent compressive sensing rebuilding, effective domain-independent solutions [28]. It also encouraged machine learning in data compression. The method was computationally complex. The matrix made the compressed sensing approach complicated [15, 19–22]. By employing level 1 with the wavelet Db3, levels 2, 3 with the wavelets Db2, and level 4 with Db1, DWT was employed to compress and denoise smart grid signal [19]. Using wavelet Db3 for level 1, Db2 for 2, 3, 4 levels and level 5 with Db1 using WPT, it reduced and cleaned smart grid data [20]. The novel approach integrated level 1 with Db3, level 2 with Db2, and level 3 with Db1 using the wavelet packet transform [21]. It used a Db4 wavelet at level 3 to compress the voltage sag signal via wavelet transform [22].

The reconstruction error and compression ratio can be improved, and the complexity can be further reduced. Consequently, the novel approach proposes integration of several minimum-order wavelet functions and a levelbased

suitable threshold by employing discrete wavelet transform. Achieving excellent compression and reconstruction by decomposing at level 3 simplify the process. The outcomes will be compared with those of [15, 20–23].

II. SYSTEM DEVELOPMENT

A strong mathematical tool for analyzing non-stationary signals in terms of time-frequency was Discrete Wavelet Transform. For signal analysis, multi-resolution filter banks were employed. Time-domain discrete data was converted to time-frequency domain using the Discrete Wavelet Transform. A signal was sent through a number of filters to determine its DWT. A high pass filter, HPF and a lower pass filter, LPF were applied to the signals at the same time. Each level of decomposition resulted in the branching of the input data into two outputs, one corresponding to the input signal's upper half-band and the other to its lower half-band. Half of the input data for each branch was used as the sampling rate. The overall sample rate stayed the same as a result. Only the lowest half-band branch of the DWT has undergone decomposition. For many signals, the most crucial details were included in lower-frequency part to identify the signal. The contents in high-frequency provided signal details. The high-scale or low-frequency components were used as an approximation. The lower-scale, high-frequency components were the details. The coefficients were the values of the converted data in the time-frequency. Whereas the coefficients with big absolute values conveyed more information about the data than noise, the coefficients with lower absolute values were dominated by noise. The wavelet coefficients were either cancelled out to zero (hard threshold) or reduced (soft threshold) in the second phase if they did not cross a predetermined threshold level. Reconstructing the signal from the resulting coefficients utilizing Inverse Discrete




Fig. 1. Proposed approach for compression and reconstruction

The signal in Fig. 1 is divided into approximate and detail elements using DWT, and after it is reconstructed using IDWT. The compressing method uses the Daubechies filters Db3, Db2, and Db1 at levels 1 through 3, and the reconstruction process uses the same filters in reverse. When the voltage sag signal is generated in SIMULINK in MATLAB 2021a, a waveform including 357, 379, 412, 501, and 512 samples (data points) is produced. There is a voltage sag signal that represents the load voltage data.

Both high and low pass filters are applied to the set of input data a_0 , length N in this procedure. The coefficients of each filter are $N/2$. The coefficients of approximation a_1 at resolution level one, are the outcome of LPF. The detail coefficients d_1 of the level first resolution are the outcome of HPF. For a second pair of wavelets, a_1 can be applied as the input to generate the coefficients of approximation a_2 and, details d_2 at second level resolution. The procedure continues up to resolution level 3. At each level, the detail coefficients are subjected to hard thresholding. The coefficients a_{22} is produced during reconstruction using the detail coefficients after hard thresholding d_{33} and the pure approximation coefficients a_3 . To retrieve the signal a_0 , the operation will be repeated continually.



III. WORKING OF CIRCUIT

The proposed design is evaluated using the performance metrics provided below. It communicates the compressed signal as a percentage of the compression ratio (% CR), like in (1). The lower the percentage of CR, the better the compression. The normalized root mean square error, or NRMSE, is employed to calculate the reconstruction signal error for the proposed design in accordance with “(2)” in [16] and [17]. Reconstruction is better when the reconstruction error is lower. In (3), the variable e represents the percentage relative error and in (4) it shows how the percentage of rebuilding, determines the existing design’s effectiveness [5, 15].

$$\%CR = \frac{N'}{N} \times 100 \quad (1)$$

$$NRMSE = \sqrt{\frac{\sum_{i=0}^{N-1} [x(i) - xr(i)]^2}{N^2}} \quad (2)$$

$$(\% \text{ relative error}) = \frac{[\sum_{i=0}^{N-1} [x(i) - xr(i)]]}{x(i)} \times 100 \quad (3)$$

$$\% \text{Reconstruction} = 100 - e \quad (4)$$

The initial and regenerated signals are represented by $X(i)$ and $X_r(i)$, respectively. N' represents number for nonzero coefficients by threshold and N is original samples number

IV. RESULTS, DISCUSSION OF RESULTS AND CONTRIBUTIONS OF THE RESEARCH

The following waveforms in MATLAB 2021a illustrate the outcomes of the suggested design, with the original signal or reconstructed signal amplitude in pu (per unit) on the y-axis and the number of samples on the x-axis.

Fig. 2 (a) to Fig. 6 (a) display the voltage sag signals of the original samples, while Fig. 2 (b) to Fig. 6 (b) display the signals which are regenerated using the recommended design. Fig. 2 (b) illustrates the reconstructed signal with an $NRMSE$ of 4.13×10^{-4} , which is 99.99%, from the 357 original samples in Fig. 2 (a). For the 379 original samples displayed in Fig. 3 (a), 99.99% reconstructed signal with $NRMSE$ 4.64×10^{-4} is displayed in Fig. 3 (b). For the 412 original samples shown in Fig. 4 (a), the 99.99% reconstructed signal with $NRMSE$ 3.80×10^{-4} is shown in Fig. 4 (b). For the 501 original samples in Fig. 5 (a), the 99.94% reconstruction signal with $NRMSE$ 3.29×10^{-4} is displayed in Fig. 5 (b). For the 512 original samples in Fig. 6 (a), the 99.98% reconstructed signal with $NRMSE$ 2.74×10^{-4} is illustrated in Fig. 6 (b). The results are better than [15, 20–23]. The signal is more distorted for highly compressed signal. The signal is approximately reconstructed best for 512 voltage sag original samples with 99.98% reconstruction and smallest $NRMSE$




Fig. 2. (a) Original voltage sag of 357 samples



International Journal of Multidisciplinary Research in Science, Engineering and Technology (IJMRSET)

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)




Fig. 2. (b) reconstruction 99.99% using DWT-based proposed design




Fig. 3. (a) Original voltage sag of 379 samples




Fig. 3. (b) reconstruction 99.99% using DWT-based proposed design




Fig. 4. (a) Original Voltage sag of 412 samples



International Journal of Multidisciplinary Research in Science, Engineering and Technology (IJMRSET)

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)




FIG. 4. (B) RECONSTRUCTION 99.99% USING DWT-BASED PROPOSED DESIGN




FIG. 5. (A) ORIGINAL VOLTAGE SAG OF 501 SAMPLES




FIG. 5. (B) RECONSTRUCTION 99.94% USING DWT-BASED PROPOSED DESIGN.




FIG. 6. (A) ORIGINAL VOLTAGE SAG OF 512 SAMPLES AND.




FIG. 6. (B) RECONSTRUCTION 99.98% USING DWT-BASED PROPOSED DESIGN

V. EXPECTED CONCLUSION

This paper's goal is to compress and recreate smart grid voltage sag signals from different samples using proposed technique with discrete wavelet transform. Level 3 decomposes the signal in the suggested configuration. The suggested solution uses fewer lower order wavelet filters, which decreases complexity even though it produces more data compression than previous results. The suggested design attains CR 19.05% and NRMSE 4.13×10^{-4} with 99.99% reconstruction for 357 original voltage sag samples. With an NRMSE of 2.74×10^{-4} and a 99.98% reconstruction, it achieves CR 19.34% for 512 original voltage sag samples. Data compression, reconstruction error, and percentage reconstruction have all improved considerably compared to previous studies.

REFERENCES

- [1] M. Asaad, F. Ahmad, M. S. Alam, M. Sarfraz, "Smart grid and Indian experience: A review," *Resour. Policy*, 2019. doi: 10.1016/j.resourpol.2019.101499
- [2] M. Tcheou, L. Lovisolo, M. Ribeiro et al., "The compression of electric signal waveforms for smart grids: State of the art and future trends," *IEEE Trans. Smart Grid*, vol. 5, no. 1, pp. 291–302, 2014. doi: 10.1109/TSG.2013.2293957
- [3] Z. Uddin, A. Ahmad, A. Qamar, M. Altaf, "Recent advances of the signal processing techniques in future smart grids," *Human-centric. Comput. Inf. Sci.*, vol. 8, no. 1, 2018. doi: 10.1186/s13673-018-0126-9
- [4] B. A. Bhuiyan, M. W. Absar, and A. Roy, "Performance International Journal of Electrical and Electronic Engineering and Telecommunications Vol. 14, No. 4, 2025 217 comparison of various wavelets in compression of PMU generated data in smart grid," in Proc. 3rd Int. Conf. Electr. Inf. Commun. Technol., 2018. doi: 10.1109/EICT.2017.8275177
- [5] L. Amaya and E. Inga, "Compressed sensing technique for the localization of harmonic distortions in electrical power systems," *Sensors*, vol. 22, no. 17, pp. 1–22, 2022.
- [6] E. Y. Hamid and Z. I. Kawasaki, "Wavelet-based data compression of power system disturbances using the minimum description length criterion," *IEEE Trans. Power Deliv.*, vol. 17, no. 2, pp. 460–466, 2002.
- [7] J. C. S. Souza, T. M. L. Assis, and B. C. Pal, "Data compression in smart distribution systems via singular value decomposition," *IEEE Trans. Smart Grid*, vol. 8, no. 1, pp. 275–284, 2017.
- [8] T. Song, X. Wang and R. Sha, "A fusion lossy and lossless data compression method based on signal attributes," in Proc. 2024 7th Int. Conf. on Data Science and Information Technology, Nanjing, China, 2024. doi: 10.1109/DSIT61374.2024.10881307
- [9] A. Özbek, X. L. Deán-Ben, and D. Razansky, "Universal real-time adaptive signal compression for high-frame-rate optoacoustic tomography," *IEEE Trans. on Medical Imaging*, vol. 41, no. 10, pp. 2903–2911, Oct. 2022.
- [10] B. An, T. Xiao, J. Wang, Z. Sui, D. Liu, and M. Li, "IGBT massive data compression based on the adaptive threshold wavelet compression algorithm," in Proc. 2022 IEEE 11th Data Driven Control and Learning Systems Conf., Chengdu, China, 2022. doi: 10.1109/DDCLS55054.2022.9858497
- [11] D. Kolomenskiy, R. Onishi, and H. Uehara, "WaveRange: Wavelet-based data compression for three-dimensional numerical simulations on regular grids," *Journal of Visualization*, vol. 25, no. 3, pp. 543–573, 2022.
- [12] M. R. Chowdhury, S. Tripathi, and S. De, "Adaptive multivariate data compression in smart metering internet of things," *IEEE Trans. on Industrial Informatics*, vol. 17, no. 3, pp. 1–11, 2020. doi: 10.1109/TII.2020.2981382



International Journal of Multidisciplinary Research in Science, Engineering and Technology (IJMRSET)

(A Monthly, Peer Reviewed, Refereed, Scholarly Indexed, Open Access Journal)

- [13] N. Hashemipour, J. Aghaei, A. Kavousi-fard et al., "Optimal singular value decomposition based big data compression approach in smart grids," *IEEE Trans. Ind. Appl.*, vol. 57, no. 4, pp. 3296–3305, 2021.
- [14] F. A. D. O. Nascimento, R. G. Saraiva, and J. Cormane, "Improved transient data compression algorithm based on wavelet spectral quantization models," *IEEE Trans. Power Deliv.*, vol. 35, no. 5, pp. 2222–2232, 2020.
- [15] M. Ruiz and I. Montalvo, "Electrical faults signals restoring based on compressed sensing techniques," *Energies*, vol. 13, no. 8, 2020. doi: 10.3390/en13082121
- [16] J. Khan, S. Bhuiyan, G. Murphy, and J. Williams, "Data denoising and compression for smart grid communication," *IEEE Trans. Signal Inf. Process. over Networks*, vol. 2, no. 2, pp. 200–214, 2016.
- [17] J. Khan, "International journal of electrical power and energy systems weighted entropy and modified MDL for compression and denoising data in smart grid," *Int. J. Electr. Power Energy Syst.*, vol. 133, 2021. doi: 10.1016/j.ijepes.2021.107089
- [18] R. Jadhav and A. Mahajan, "Review on data compression methods of smart grid power system using wavelet transform," in Proc. 1st Int. Conf. on Smart Energy and Advancement in Power Technologies, Jamshedpur, pp. 237–255, 2023. doi: 10.1007/978-981-19-4971-5_18
- [19] R. Y. Jadhav and A. Mahajan, "Data compression and noise reduction in smart grid using discrete wavelet transform," *Traitement du Signal*, vol. 39, no. 5, pp. 1857–1863, 2022.
- [20] R. Jadhav and A. Mahajan, "Smart grid data denoising and compression using wavelet packet transform," *Mathematical Modelling of Engineering Problems*, vol. 10, no. 4, pp. 1433–1440, 2023.
- [21] R. Jadhav and A. Mahajan, "Smart grid data compression and reconstruction by wavelet packet transform," *MethodsX*, vol. 13, no. July, 2024. doi: 10.1016/j.mex.2024.102872
- [22] K. M. Jose, "Smart grid data compression of power quality events using wavelet transform," in Proc. 2022 IEEE Canadian Conf. on Electrical and Computer Engineering, 2022, pp. 159–164.
- [23] V. Loia, S. Tomasiello, and A. Vaccaro, "Fuzzy transform based compression of electric signal waveforms for smart grids," *IEEE Trans. Syst. Man, Cybern. Syst.*, vol. 47, no. 1, pp. 121–132, 2017.
- [24] A. Gálvez, A. Iglesias, I. Fister and I. Fister, "Industrial artificial intelligence approach for shape reconstruction in quality assessment of digital data from manufactured workpieces," in Proc. 2023 4th International Conference on Industrial Engineering and Artificial Intelligence (IEAI), Chiang Mai, Thailand, 2023, pp. 86–93. doi: 10.1109/IEAI59107.2023.00020
- [25] X. Zhang and J. Saniie, "Data Compression for Ultrasonic Microstructure Scattering Signals using Unsupervised Neural Networks," in Proc. 2023 IEEE International Ultrasonics Symposium (IUS), Montreal, QC, Canada, 2023, pp. 1–3. doi: 10.1109/IUS51837.2023.10308084
- [26] H. Zhan, "Image compression and reconstruction based on GUI and Huffman coding," *Journal of Physics: Conference Series. Institute of Physic*, vol. 2580, no. 1, 2023. doi: 10.1088/1742-6596/2580/1/012025



ISSN

INTERNATIONAL
STANDARD
SERIAL
NUMBER
INDIA



INTERNATIONAL JOURNAL OF MULTIDISCIPLINARY RESEARCH IN SCIENCE, ENGINEERING AND TECHNOLOGY

| Mobile No: +91-6381907438 | Whatsapp: +91-6381907438 | ijmrset@gmail.com |